



Product Service

Attestation of Conformity

No. N8A 17 03 52840 031

Holder of Certificate: Samwon Act Co., Ltd.

28, Daedong-ro, Sasang-gu

Busan 47035

REPUBLIC OF KOREA

Product: Low voltage switchgear combination
(Terminal block)**Model(s):** SPxy-w-z**Parameters:**

Rated input voltage:	600 V a.c. max.
Rated frequency:	50/60 Hz
Pollution degree:	3
Overvoltage category:	III
Rated Impulse withstand voltage(Uimp):	6 KV

**Tested
according to:**

EN 60947-1:2007/A1:2011

EN 60947-7-1:2009

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.:

CPSA01397016

Date, 2017-03-22

(Hyuk-Jun Kwon)



After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity**No. N8A 17 03 52840 031****Description of Model name**

SPxy-w-z

x. Input terminal type

S – Screw type

D – Tab type

y. Rating current

25 – 75A

30 – 100A

35 – 150A

w. Screw size

M6 – M6

M8 – M8

Blank – None

z. Output type

6*M4

9*M4

3*M5

6*M5

3*M6

5*M6